

**PLEASE NOTE:** IT IS RECOMMENDED FOR ESTER OIL OR WHERE TRANSFORMERS ARE BEING USED FOR RENEWABLE ENERGY, THAT BUSHINGS BE SUPPLIED WITH AVS CONE RUBBERS & NEBAR CORK GASKETS.

KINDLY SPECIFY THE APPLICATION WHEN ORDERING.

## 600V Terminal Immersed Bushings



Part Number	Description	U.m (kV)	Ir (A)	Material	Tank Hole Size (mm)	Stem Thread Size	Stem Pitch (mm)	Recommended Torque (N.m)
040-006	B6	0.6	45	PA6 Black Nylon	15	M6	1	2
040-035	BS6	0.6	45	PA6 Black Nylon	12	M6	1	2
040-007	B8	0.6	60	PA6 Black Nylon	21	M8	1,25	3,5
040-008	B10	0.6	80	DMC	22	M10	1,5	8
040-009	B12	0.6	120	DMC	25	M12	1,75	16
040-025	NB6	0.6	45	DMC	19	M6	1	2
040-026	NB8	0.6	60	DMC	19	M8	1,25	3,5
040-034	NB8 - 3.3	3.3	60	DMC	19	M8	1,25	3,5
040-027	NB10	0.6	80	DMC	22	M10	1,5	8

**\* Note:**

Detailed drawings available on request.

Tank wall thickness minimum 3mm , maximum 6mm

Tank hole size tolerance is -0mm +1mm

AVS Cone rubbers see page 243

AVS- Allbro Veri Seal

Enclosures

Hinges

Locks

Handles

Accessories

Rotary Operating Handles

Insulators

Transformer Equipment

Index